PHYSICAL TESTING REPORT





FAO: Mr. David Morgan

Report of Tests on: Coala Floor Lam 2D **Your Reference:** Coala Floor Lam 2D **Lucideon Reference:** UK202760-19862

Date Reported:

09-Jul-2020

Order Number:

PO 122419

08-Jul-2020

to 08-Jul-2020

Date Logged:

07-Jul-2020

Date(s) of Test(s):

Inclined Platform Test for Slip Resistance In Shod Conditions

DIN 51130:2014

	Operator 1 - Angle of Inclination	Operator 2 - Angle of Inclination
No.	•	•
1	5.6	6.1
2	5.7	5.8
3	5.4	6.7

Description of Test Specimen(s): Coala Floor Lam 2D sheet

Average of Six Shod Results (Corrected): 7.4 °

Category: R9

The critical angle at which a test person reaches the limit of safe walking on an inclined plane is used as a measure of slip resistance.

Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.

End of Test Report



Lucideon Limited