



Antalis
8 rue de Seine
F-92100 Boulogne-Billancourt
France

Your message - reference

Coala Interior Film Exterior

our reference

JW/3362

Gent

2024-09-26

Certification report 24/3362

1. Description of the material:

type	Self-adhesive film composed of: 1 Backing paper – 2 PSA – 3 Base Film (PMMA or PVC) – 4 Print - 5 Coating
Thickness	215 – 250 µm
Weight	Ca. 240 g/m ²

2. Test executed:

EN ISO 11925-2 (exposure=30s)	EN 13823
----------------------------------	----------

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.
Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

addressee

Antalis

our reference

JW/3362

Gent

2024-09-26

page

2

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows according EN 13501-1:2018:

D – s1, d0

Used over a Aluminium 1mm and density of 2700 kg/m³ and all substrates classified A1 which density is superior to 2025 kg/m³ and having a fusion point superior or equal to 500°C

The evaluation of this properties is based on evaluation scheme specified in EN 13501-1:2019: Fire classification of construction products and building elements - Part 1: Classification using data from reaction to fire tests.

Products falls under system 3 of assessment and verification of constancy of performance like declared by the manufacturer.

Related commercial names to this product group	EXT-Z10 / EXT-Z11 / EXT-Z12 EXT-Z13 / EXT-Z14 / EXT-Z15 EXT-Z16 / EXT-Z17 / EXT-Z18 EXT-Z19 / EXT-Z20
The obtained classification is based on the next test report(s)	CREPIM: DO-24-5826\A-R1 issued on 15-03-2024 CREPIM: DO-24-5826\B-R1 issued on 15-03-2024
Validity of the certificate	2029-03-14

Jo Wynendaele PhD

Consultant Floor and Wall Coverings

