

Laboratory approved by the Ministry for the Interior

JO of February 10, 2007

OFFICIAL REPORT OF CLASSIFICATION OF FIRE PERFORMANCE

Of A MATERIAL ENVISAGED IN ARTICLE 5

DECREE OF November 21, 2002

N° CM - 19 - P - 075

et 1 annexe de 4 pages.

Page 1

Valid 5 years as from mardi 4 juin 2019

Material presents by : **MOSAÏCO S.R.L**

Via Piave 1

36030 ALTAVILLA VICENTINA

Trade mark: **SOLARIS FLAM**

Summary description

Kind papier

Composition papier ignifugé

Mass per unit area 120 à 320 g/m²

Tickness 0,2 à 0,4 mm (données laboratoire FCBA)

Color blanc

Nature of the test : Electrical burner test

Classification : **M1**

Observations : /

Durability of the classification (Article 5 de l'annexe 2) 12 months starting from the implementation in a regulated building

Usual term Walls hung covering, sheers, curtains,...

Cleaning conditions Not washable with water and not cleanable

Taking into account the criteria resulting from the tests annexed described in the test report N^{FE} 19-0184-0859

This official report attests only characteristics of the sample submitted for testing and does not prejudice similar characteristics of products. It thus does not constitute a certification of products within the meaning of the L.115-27 article of the code of the consumption and the law of June 3rd, 1994.

NOTE: The integral reproductions and by photocopy of this official report of classification are only authorized or the official report unit of classification and report of annexed test. These conclusions relate only to the resistance / reaction to fire performance of the element that is the subject of the present classification report. They do not prejudice, in any case, other performances related to its incorporation to a work "

"Not legally acceptable for any use under the pretence of the article AM 18 (Decree of March 6th, 2006) for upholstered seat"


Champs-sur-Marne, le jeudi 13 juin 2019

Technicienne d'essais
du Laboratoire Feu

Clotilde ETIEMVRE

Responsable Technique du Laboratoire
Feu

Pôle Ameublement


Clemence RAWAS

Only the french version remains valid

Institut technologique FCBA : Forêt, Cellulose, Bois - construction, Ameublement